

Freezer

BTU/hr @ 75° F Ambient & -10° F Freezer DDS LED Lighting

Doors	2467	2475	2667	2675	2679	2867	2875	2879	3067	3075	3079	3081	3681
1	1164	1283	1238	1360	1423	1306	1434	1499	1378	1515	1585	NA	NA
2	2132	2355	2273	2507	2629	2403	2653	2779	2541	2807	2928	NA	NA
3	3045	3453	3341	3683	3861	3485	4688	4071	3641	4134	4321	NA	NA
4	4123	4549	4415	4857	5102	4670	5150	5375	4941	5466	5711	NA	NA
5	5125	5656	5484	6031	6335	5807	6396	6679	6150	6794	7089	NA	NA

Cooler High Humidity

BTU/hr @ 75° F Ambient & 38° F Cooler DDS LED Lighting

Doors	2467	2475	2667	2675	2679	2867	2875	2879	3067	3075	3079	3081	3681
1	730	817	776	863	916	819	912	966	865	967	1018	695	641
2	1429	1599	1523	1696	1795	1612	1795	1888	1703	1895	2002	970	1075
3	2119	2377	2271	2524	2680	2404	2676	2815	2540	2835	2981	NA	NA
4	2829	3160	2626	3353	3562	3000	3555	3740	3378	3768	3969	NA	NA
5	3531	3947	3766	4182	4445	3990	4429	4665	4219	4700	4949	NA	NA

Cooler

BTU/hr @ 75° F Ambient & 38° F Cooler DDS LED Lighting

Doors	2467	2475	2667	2675	2679	2867	2875	2879	3067	3075	3079	3081	3681
1	257	291	274	312	323	287	329	344	302	351	366	410	438
2	479	543	513	587	612	546	625	650	582	664	695	597	669
3	704	799	759	861	888	807	915	959	860	976	1022	NA	NA
4	926	1056	1002	1135	1188	1066	1210	1266	1135	1289	1210	NA	NA
5	1152	1308	1243	1410	1477	1326	1502	1576	1413	1602	1679	NA	NA

DESIGN NOTE: Add 15 - 25% to the values depending on the door opening frequency

